

- The use of accessory equipment not recommended by the manufacturer or installed contrary to instructions may cause an unsafe condition. The use of damaged components may cause an unsafe condition and void product warranty.
- marked on fixture label.
- All gaskets, o-rings and sealing surfaces must be kept clean during installation and service; failure to do this may cause an unsafe condition and void product warranty.

IMPORTANT LISTINGS AND CERTIFICATIONS

Suitable for wet locations

from skin may damage lamp.


Do not operate the luminaire fitting with a missing or

damaged shield.

SAVE THESE INSTRUCTIONS

· Additionally suitable for mounting within 4 ft. of the ground


Please refer to the low voltage design guide at www.bklighting.com/lvguide before installation for proper wire selection.














REFERENCE NUMBER

IMPORTANT SAFETY INFORMATION - READ, FOLLOW, AND SAVE THESE INSTALLATION INSTRUCTIONS




40429 Brickyard Drive • Madera, CA 93636 • USA 559.438.5800 • FAX 559.438.5900 RELEASE DATE 4-27-18 www.bklighting.com • info@bklighting.com

INS001389


BC12

THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF B-K LIGHTING, INC. AND ITS RECEIPT OR POSSESSION DOES NOT CONVEY ANY RIGHTS TO REPRODUCE, DISCLOSE ITS CONTENTS, OR TO MANUFACTURE, USE OR SELL ANYTHING IT MAY DESCRIBE. REPRODUCTION, DISCLOSURE OR USE WITHOUT SPECIFIC WRITTEN AUTHORIZATION OF B-K LIGHTING, INC. IS STRICTLY FORBIDDEN.







Phase 2 - Fixture Installation



- 1. Mount knuckle onto suitable enclosure according to designed lighting plan.
- 2. Secure 1/2" NPS stem to mounting option. Secure with provided locknut if applicable.




Make watertight connections from remote 12V 3. transformer to fixture leads using waterproof wire connectors (By Others).



voltage connections (See Wiring diagram).


4. Mount canopy with hardware provided or use appropriate hardware best suited for architecture structure. Seal building envelope as per NEC.

Phase 3 - Finish Installation of Canopy with provided Universal Ring.



Install universal mounting ring (supplied with canopy) onto installed junction box using supplied #10-24 screws. Align faceplate mounting holes to final mounting position.

B-K LIGHTING



Make watertight connections from remote

transformer to fixture leads using waterproof wire connectors (By Others). See wiring

(6)

3. Mount fixture using two (2) #10-24 hex screw to installed back box. Seal building envelope as per NEC. Do not over tighten.

IMPORTANT SAFETY INFORMATION LISTED ON REVERSE

diagram.

2.



REFERENCE NUMBER INS001389

40429 Brickyard Drive • Madera, CA 93636 • USA 559.438.5800 • FAX 559.438.5900 www.bklighting.com • info@bklighting.com

RELEASE DATE 4-27-18

READ, FOLLOW, AND SAVE ALL SAFETY AND INSTALLATION INSTRUCTIONS