

INSTRUCTIONS PERTAINING TO A RISK OF FIRE, OR INJURY TO PERSONS IMPORTANT SAFETY INSTRUCTIONS

Lighted fixture is HOT! WARNING - To reduce the risk of FIRE OR INJURY TO PERSONS:

Turn off/unplug and allow to cool before replacing lamp/LED. Fixture gets HOT quickly! Contact only switch/plug when turning on. Do not touch hot lens, guard, or enclosure. Keep fixture away from materials that may burn. Do not operate the luminaire fitting with a missing or damaged shield. Do not touch the source at any time. Use a soft cloth or gloves. Oil from skin may cause damage.

SAVE THESE INSTRUCTIONS


IMPORTANT SAFETY INFORMATION - READ, FOLLOW, AND SAVE ALL SAFETY AND INSTALLATION INSTRUCTIONS

- Product must be installed by a qualified person in a manner consistent with its intended use and in compliance with the National Electrical Code, Canadian Electrical Code, and all Local and Provincial Codes.
- Follow product label information and instructions.
- Qualified Personnel with appropriate personal protective equipment must perform all servicing of this product.
- Before wiring to power supply and during servicing, turn off and lock out power at fuse or circuit breaker before service.
- The use of accessory equipment not recommended by the manufacturer or installed contrary to instructions may cause an unsafe condition. The use of damaged components may cause an unsafe condition and void product warranty.
- Do not block light emanating from product in whole or part, as this may cause an unsafe condition.
- Never operate the fixture with missing or damaged lens. Lens must be cleaned on regular basis.
- Entire fixture may become extremely hot. Do not touch hot lens or fixture body.
- Replace LED assembly only with correct wattage and type of power supply appropriate for LED assembly.
- All gaskets, o-rings and sealing surfaces must be kept clean during installation and service; failure to do this may cause an unsafe condition and void product warranty.


IMPORTANT LISTINGS AND CERTIFICATIONS

Suitable for wet location
Additionally suitable for mounting within 4 ft. of the ground
Type Non-IC


Please refer to the low voltage design guide at www.bklighting.com/lvguide before installation for proper wire selection.



THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF B-K LIGHTING, INC. AND ITS RECEIPT OR POSSESSION DOES NOT CONVEY ANY RIGHTS TO REPRODUCE, DISCLOSE ITS CONTENTS, OR TO MANUFACTURE, USE OR SELL ANYTHING IT MAY DESCRIBE. REPRODUCTION, DISCLOSURE OR USE WITHOUT SPECIFIC WRITTEN AUTHORIZATION OF B-K LIGHTING, INC. IS STRICTLY FORBIDDEN.




- Please follow National and Local electrical codes for your
 - Suitable for installation into combustible materials.
- Orientation of installed back box determines faceplate screw



- Mount MB2 box to surface using mounting hardware (included) using the mounting brackets attached to back of MB2 box.
- Alternative mounting methods may compromise integrity of MB2 against water intrusion and will void warranty.
- Connect box to conduit and pull wires for connections (See Wiring diagram).

Phase 2 - Finish Installation of Fixture with Remote Transformer




warranty.

WIRING DIAGRAM

- ▲ LED For use with 12VAC LED remote transformer or magnetic transformers only. B-K Lighting cannot guarantee performance with third party manufacturers' transformers.
- Make watertight connections from remote 1. transformer to LED leads using waterproof wire connectors (not included). See wiring diagram.



To aim, loosen the two (2) phillips screws attaching the adjustable bracket to the faceplate. Aim to desired position. Tighten two (2) phillips screws to 2. lock in place when desired angle is set.




Mount faceplate using two (2) #10-24 screws with a 1/8" allen wrench. Tighten evenly to compress 3. gasket. Do not over tighten.





B-K LIGHTING 559.438.5800 • FAX 559.438.5900 www.bklighting.com • info@bklighting.com 07/11/2023

REFERENCE NUMBER INS001003



- 7. With flat head screw driver rotate dial to desired lumen output.
- 8. Attach bracket to faceplate by securing two (2) phillips screws. Aim to desired position. Tighten two (2) phillips screws to lock in place when desired angle is set.
- Mount faceplate using two (2) #10-24 screws with a 1/8" allen wrench. Tighten evenly to compress gasket. Do not over tighten.

IMPORTANT SAFETY INFORMATION - READ, FOLLOW, AND SAVE THESE INSTALLATION INSTRUCTIONS



40429 Brickyard Drive • Madera, CA 93636 • USA 559.438.5800 • FAX 559.438.5900 REFERENCE NUMBER RELEASE DATE 07/17/2023 INS000022 www.bklighting.com • info@bklighting.com

9.

THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF B-K LIGHTING, INC. AND ITS RECEIPT OR POSSESSION DOES NOT CONVEY ANY RIGHTS TO REPRODUCE, DISCLOSE ITS CONTENTS, OR TO MANUFACTURE, USE OR SELL ANYTHING IT MAY DESCRIBE. REPRODUCTION, DISCLOSURE OR USE WITHOUT SPECIFIC WRITTEN AUTHORIZATION OF B-K LIGHTING, INC. IS STRICTLY FORBIDDEN.